

# Контрольные замеры по ПС 35/6 кВ Кольцово\*

Дата: 21.06.2017 г.

3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	1:00	2:00
------	------	------	------	------	------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------	------	------

## Трансформаторы

ДН	Класс U	СШ(С)	dPкз	Uк	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I
№1	35	1С	0,000	0,000																							
	6	1С	0,000	0,000	338,0	338,0	338,0	339,0	340,0	375,0	377,0	380,0	375,0	378,0	360,0	365,0	362,0	372,0	380,0	388,0	386,0	371,0	385,0	371,0	375,0	362,0	361,0
Положение РПН (ПБВ) / ВДТ:																											
№2	35	2С	0,000	0,000																							
	6	2С	0,000	0,000	344,0	329,0	311,0	316,0	314,0	322,0	333,0	371,0	376,0	385,0	381,0	386,0	409,0	438,0	433,0	427,0	418,0	414,0	389,0	384,0	355,0	356,0	339,0
Положение РПН (ПБВ) / ВДТ:																											

## Шины (секции)

Класс U	Подключение	U	U	U	U	U	U	U	U	U	U	U	U	U	U	U	U	U	U	U	U	U	U	U	U	U	U
35	T1 - ВН																										
35	T2 - ВН																										
6	T1 - НН																										
6	T2 - НН																										

## Присоединения

ДН	Уст.АЧР1		Уст.АЧР2		Уст.ЧАПВ		Уст.СОАЧР		I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I	I				
	Гц	сек	Гц	сек	Гц	сек	Гц	сек																								
1С 35 кВ																																
Н.Исетская																																
2С 35 кВ																																
Родник																																
ЗРУ №1																																
1С 6 кВ																																
ТП 22 ф.2									25,0	25,0	25,0	25,0	25,0	25,0	25,0	25,0	25,0	25,0	25,0	25,0	25,0	25,0	25,0	25,0	25,0	25,0	25,0	25,0				
ТП 14 ф.4									6,0	6,0	6,0	6,0	6,0	6,0	6,0	6,0	6,0	6,0	6,0	6,0	8,0	5,0	5,0	6,0	6,0	8,0	7,0	7,0	6,0			
ТП 26 ф.6									5,0	5,0	5,0	5,0	5,0	10,0	10,0	10,0	10,0	10,0	10,0	10,0	10,0	10,0	10,0	10,0	10,0	10,0	10,0	10,0				
ТП 10 ф.9									5,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0				
ТП 70002 ф.10									1,0	1,0	1,0	1,0	1,0	2,0	3,0	4,0	3,0	4,0	4,0	4,0	3,0	2,0	2,0	1,0	1,0	1,0	1,0	1,0				
ТП 39 ф.32									0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0				
ТП 21 ф.33									2,0	2,0	2,0	2,0	2,0	2,0	2,0	2,0	3,0	3,0	3,0	3,0	2,0	2,0	2,0	2,0	2,0	2,0	2,0	2,0				
2С 6 кВ																																
ТП 12 ф.18									5,0	4,0	3,0	3,0	5,0	4,0	5,0	5,0	3,0	5,0	5,0	4,0	6,0	6,0	5,0	5,0	5,0	6,0	6,0	6,0	7,0	5,0		
ТП 20 ф.19									10,0	9,0	9,0	9,0	9,0	9,0	9,0	8,0	8,0	9,0	9,0	9,0	9,0	9,0	9,0	9,0	9,0	9,0	9,0	9,0	9,0			
ТП 10 ф.20									9,0	10,0	10,0	10,0	10,0	15,0	15,0	15,0	15,0	15,0	15,0	16,0	17,0	15,0	15,0	10,0	10,0	10,0	9,0	9,0	9,0			
ТП 26 ф.21									0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0			
ТП 14 ф.26									1,0	1,0	1,0	1,0	1,0	1,0	1,0	1,0	1,0	1,0	1,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0	5,0				
ТП 36 ф.27									0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0				
ТП 13 ф.30									0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0			
ТП 22 ф.31									0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0			
ЗРУ №2																																
1С 6 кВ																																
ТП 7 ф.2									39,0	39,0	36,0	36,0	35,0	35,0	36,0	36,0	36,0	36,0	35,0	36,0	36,0	37,0	37,0	36,0	37,0	36,0	36,0	31,0	29,0	29,0	28,0	30,0
ТП 11 ф.3									19,0	16,0	36,0	24,0	21,0	32,0	23,0	30,0	34,0	33,0	10,0	22,0	14,0	10,0	23,0	30,0	35,0	15,0	19,0	14,0	13,0	24,0	21,0	27,0
ТП 9 ф.4									0,0	0,0	0,0	0,0	19,0	21,0	23,0	22,0	22,0	22,0	23,0	23,0	24,0	25,0	22,0	28,0	29,0	29,0	25,0	24,0	19,0	0,0	0,0	12,0
ТП 1 ф.8									26,0	31,0	26,0	30,0	27,0	33,0	31,0	25,0	26,0	24,0	25,0	21,0	24,0	24,0	21,0	21,0	21,0	22,0	42,0	40,0	38,0	47,0	53,0	30,0
ТП 3 ф.9									12,0	13,0	11,0	10,0	11,0	8,0	7,0	9,0	10,0	10,0	9,0	10,0	9,0	13,0	10,0	11,0	12,0	9,0	10,0	10,0	9,0	8,0	9,0	
ТП 5 ф.10									30,0	30,0	29,0	29,0	28,0	29,0	29,0	31,0	31,0	32,0	31,0	32,0	33,0	37,0	34,0	33,0	32,0	33,0	36,0	30,0	33,0	28,0	31,0	29,0
ТП 75001 ф.12									168,0	165,0	156,0	164,0	155,0	167,0	173,0	175,0	164,0	168,0	174,0	168,0	169,0	176,0	177,0	176,0	170,0	175,0	169,0	173,0	182,0	175,0	170,0	162,0
2С 6 кВ																																
ТП 2 ф.18									26,0	28,0	28,0	28,0	30,0	29,0	29,0	31,0	32,0	33,0	33,0	32,0	33,0	35,0	37,0	40,0	40,0	38,0	40,0	39,0	31,0	34,0	34,0	30,0
ТП 4 ф.19									31,0	28,0	28,0	30,0	25,0	23,0	24,0	24,0	22,0	24,0	23,0	24,0	27,0	26,0	24,0	27,0	27,0	28,0	27,0	25,0	25,0	25,0	26,0	28,0
ТП 6 ф.20									28,0	29,0	26,0	25,0	18,0	16,0	18,0	24,0	24,0	23,0	23,0	24,0	38,0	53,0	52,0	52,0	52,0	51,0	36,0	31,0	13,0	14,0	13,0	18,0
ТП 75001 ф.22									186,0	180,0	165,0	166,0	171,0	167,0	178,0	193,0	205,0	210,0	205,0	206,0	209,0	219,0	218,0	215,0	210,0	208,0	204,0	198,0	198,0	194,0	183,0	188,0
ТП 9 ф.25									28,0	27,0	29,0	27,0	31,0	41,0	36,0	44,0	40,0	39,0	40,0	45,0	38,0	38,0	38,0	31,0	32,0	32,0	30,0	34,0	30,0	30,0	31,0	28,0
ТП 11 ф.26									19,0	13,0	12,0	14,0	14,0	16,0	18,0	26,0	26,0	26,0	27,0	26,0	28,0	30,0	30,0	28,0	28,0	28,0	23,0	27,0	29,0	30,0	28,0	28,0
Замер провёл:																																